Energy performance certificate (EPC)

Flat 3 9 Beechcroft Avenue LONDON NW11 8BJ	Energy rating **E**	Valid until:	**20 May 2028**
		Certificate number:	**9368-0090-7255-5688-1970**

roperty type	Mid-floor flat
otal floor area	44 square metres

Rules on letting this property


operties can be let if they have an energy rating from A to E.

u can read guidance for landlords on the regulations and exemptions (https://www.gov.uk/guidance/domestic-private-rented-operty-minimum-energy-efficiency-standard-landlord-guidance).

Energy rating and score

is property's energy rating is E. It has the potential to be B.

e how to improve this property's energy efficiency.



e graph shows this property's current and potential energy rating.

operties get a rating from A (best) to G (worst) and a score. The better the rating and score, the lower your energy ls are likely to be.

r properties in England and Wales:

- the average energy rating is D
- the average energy score is 60

Breakdown of property's energy performance

eatures in this property

atures get a rating from very good to very poor, based on how energy efficient they are. Ratings are not based on how ll features work or their condition.

sumed ratings are based on the property's age and type. They are used for features the assessor could not inspect.

ature	Description	Rating
all	Solid brick, as built, no insulation (assumed)	Very poor
ndow	Fully double glazed	Average
ain heating	Room heaters, electric	Very poor
ain heating control	Programmer and appliance thermostats	Good

ıt water	Electric immersion, standard tariff	Very poor
ghting	Low energy lighting in all fixed outlets	Very good
oof	(another dwelling above)	N/A
oor	(another dwelling below)	N/A
condary heating	None	N/A

rimary energy use

e primary energy use for this property per year is 439 kilowatt hours per square metre (kWh/m2).

About primary energy use

low this affects your energy bills

average household would need to spend **£1,003 per year on heating, hot water and lighting** in this property. These sts usually make up the majority of your energy bills.

u could **save £712 per year** if you complete the suggested steps for improving this property's energy rating.

is is **based on average costs in 2018** when this EPC was created. People living at the property may use different nounts of energy for heating, hot water and lighting.

eating this property

timated energy needed in this property is:

- 2,976 kWh per year for heating
- 3,041 kWh per year for hot water

mpact on the environment

is property's environmental impact rating is E. It has the potential to be C.

operties get a rating from A (best) to G (worst) on how much carbon dioxide (CO2) they produce each year.

arbon emissions

n average household produces	6 tonnes of CO
his property produces	3.2 tonnes of CO

his property's potential production	1.8 tonnes of CC

u could improve this property's CO2 emissions by making the suggested changes. This will help to protect the vironment.

ese ratings are based on assumptions about average occupancy and energy use. People living at the property may use ferent amounts of energy.

teps you could take to save energy

Do I need to follow these steps in order?

tep 1: Internal wall insulation

ypical installation cost	£4,000 - £14,0(
ypical yearly saving	£3(
otential rating after completing step	60 D

tep 2: High heat retention storage heaters and dual nmersion cylinder and dual rate meter

ypical installation cost	£800 - £1,2(
ypical yearly saving	£41
otential rating after completing eps 1 and 2	83 B

dvice on making energy saving improvements

t detailed recommendations and cost estimates

elp paying for energy saving improvements

u may be eligible for help with the cost of improvements:

Free energy saving improvements: Warm Homes Local Grant (WHLG)

Heat pumps and biomass boilers: Boiler Upgrade Scheme
Help from your energy supplier: Energy Company Obligation

Who to contact about this certificate

Contacting the assessor

If you're unhappy about your property's energy assessment or certificate, you can complain to the assessor who created it

Assessor's name	Michael Gibber
Telephone	07843698991
Email	peninsulasurveys@me.com

Contacting the accreditation scheme

If you're still unhappy after contacting the assessor, you should contact the assessor's accreditation scheme.

Accreditation scheme	Elmhurst Energy Systems Ltd
Assessor's ID	EES/020438
Telephone	01455 883 250
Email	enquiries@elmhurstenergy.co.uk

About this assessment

Assessor's declaration	No related party
Date of assessment	16 May 2018
Date of certificate	21 May 2018
Type of assessment	▶ RdSAP

)ther certificates for this property

/ou are aware of previous certificates for this property and they are not listed here, please contact us at ıclg.digital-services@communities.gov.uk or call our helpdesk on 020 3829 0748 (Monday to Friday, 9am to 5pm).

ere are no related certificates for this property.

OGL
All content is available under the Open Government Licence v3.0 (https://www.nationalarchives.gov.uk/doc/open-government-licence/version/3/), except where otherwise stated

© Crown copyright (https://www.nationalarchives.gov.uk/information-management/re-using-public-sector-information/uk-government-licensing-framework/crown-copyright/)